#### INDEX OF SHEETS


MCPDWT (FULL SET)	
1	TITLE SHEET
2	GENERAL NOTES SHEET
3	BORING LOGS
4	ACCESS PLAN
5-6	EXISTING CONDITIONS PLAN
7-8	DREDGING PLANS
9	SITE RESTORATION PLAN
10	EROSION & SEDIMENT NOTES
11	EROSION & SEDIMENT DETAILS
12-13	EROSION & SEDIMENT CONTROL PLANS
14-16	BATHYMETRIC SURVEY
17-19	CROSS SECTIONS

# MONTGOMERY COUNTY DEPARTMENT OF ENVIRONMENTAL PROTECTION

## GUNNERS LAKE MAINTENANCE AND HYDRAULIC DREDGING

CONTRACT NO. 0801000108-AD-DD

Task Order 4



### DESIGN CERTIFICATION

I HEREBY CERTIFY THAT THIS PLAN HAS BEEN PREPARED IN ACCORDANCE WITH THE "2011 MARYLAND STANDARDS AND SPECIFICATIONS FOR SOIL EROSION AND SEDIMENT CONTROL", MONTGOMERY COUNTY DEPARTMENT OF PERMITTING SERVICES EXECUTIVE REGULATIONS 5-90, 7-02AM AND 36-90, AND MONTGOMERY COUNTY DEPARTMENT OF PUBLIC WORKS AND TRANSPORTATION "STORM DRAIN DESIGN CRITERIA" DATED AUGUST 1988.

I FURTHER CERTIFY THAT THE TOTAL AMOUNTS OF EXCAVATION AND FILL AS SHOWN ON THESE PLANS HAVE BEEN COMPUTED TO BE 20,000 CUBIC YARDS OF DREDGING AND 640 CUBIC YARDS TEMPORARY EXCAVATION AND FILL FOR STAGING AREA, THAT THE TOTAL AREA TO BE DISTURBED AS SHOWN ON THESE PLANS HAS BEEN DETERMINED TO BE A MAXIMUM OF 78,400 SQUARE FEET OR 1.80 ACRES.

DATE

CHRIS BROOKS, P.E.

P.E. # 25819

DPS PERMIT NO. TBD

MONTGOMERY COUNTY, MARYLAND
DEPARTMENT OF PERMITTING SERVICES

FINAL APPROVAL

DATE \_\_\_\_\_\_
BY \_\_\_\_\_

\*SUBJECT TO DEDICATION OF RIGHT OF WAY AND EASEMENTS PER COUNTY CODE SECTION 50.

90% SUBMISSION
NOT FOR CONSTRUCTION

## RELATED REQUIRED PERMITS BY THE CONSULTANT AND PLACED ON THE FIRST SHEET OF THE SEDIME

TO BE COMPLETED BY THE CONSULTANT AND PLACED ON THE FIRST SHEET OF THE SEDIMENT CONTROL / STORMWATER MANAGEMENT PLAN SET FOR ALL PROJECTS.

IT IS THE RESPONSIBILITY OF PERMITTEE/OWNER OF THIS SITE TO OBTAIN ALL REQUIRED PERMITS PRIOR TO ISSUANCE OF THE APPROVED SEDIMENT CONTROL PERMIT

	0_	D	3 31 11 1 3 2 1 21 11 11 1		
TYPE OF PERMIT	REQD	NOT REQD	PERMIT #	EXPIRATION DATE	WORK RESTRICTION DATES
MCDPS FLOODPLAIN DISTRICT					
WATERWAYS/WETLAND(S):					
A. CORPS OF ENGINEERS					
B. MDE					
C. MDE WATER QUALITY CERTIFICATION					
MDE DAM SAFETY					
N.P.D.E.S. NOTICE OF INTENT			N/A	N/A	DATE FILED
DNR ROADSIDE TREE PERMIT					
OTHERS (PLEASE LIST):					

## DEVELOPER'S / BUILDER'S CERTIFICATION

I HEREBY CERTIFY THAT ALL CLEARING, GRADING, CONSTRUCTION AND/OR DEVELOPMENT WILL BE DONE PURSUANT TO THIS PLAN AND THAT ANY RESPONSIBLE PERSONNEL INVOLVED IN THE CONSTRUCTION PROJECT WILL HAVE A CERTIFICATE OF ATTENDANCE OF A DEPARTMENT OF NATURAL RESOURCES APPROVED TRAINING PROGRAM FOR THE CONTROL OF SEDIMENT AND EROSION BEFORE BEGINNING THE PROJECT.

DATE	WILLIAM WHELAN

#### MCDPS SC SHEET 1 OF 18

OWNER/CONTACT/ADDRESS:

DEPARTMENT OF
ENVIRONMENTAL PROTECTION
MR. WILLIAM WHELAN
255 ROCKVILLE PIKE, STE 120

ROCKVILLE MD 20850-4166

240-777-7727

			CTION APPROVE	- •	THIS APPROVAL DOES NO OF A MCDPS ACC	
	Stormwater Mo	inagement:	Sediment Contr Requireme		Administrative	Requirement
			Reviewed	Date	Reviewed	Date
_	Reviewed	Date	Approved	Date	SEDIMENT CONTRO	)L PERMIT NO.
_	Approved	Date			MCDOT APPROVAL OF THIS PLAN THE DATE OF APPROVAL. IF THE UNLESS THE PERMIT HA	PROJECT HAS NOT STARTE
	S.M.FILE N	0.				

#### GENERAL NOTES

- I. THE CONTRACTOR WILL IMMEDIATELY INFORM THE COUNTY OF ANY DISCREPANCIES FOUND BETWEEN THE PROJECT PLANS AND CONTRACT SPECIFICATIONS.
- 2. FOR CONSTRUCTION, ALL HORIZONTAL DATUM SHALL BE BASED ON NAD 83, VERTICAL SHALL BE BASED ON
- NAVD 88 DATUM.BATHYMETRIC SURVEY PERFORMED ON NOV.2011 AND DEC.2012 BY CPJ & ASSOCIATES. 3. TYPES OF STORM DRAIN STRUCTURES REFER TO THE "DESIGN STANDARDS" OF MONTGOMERY
- COUNTY DEPARTMENT OF TRANSPORTATION, UNLESS OTHERWISE NOTED.
- 4. THE CONTRACTOR SHALL MAKE FIELD ADJUSTMENTS TO STORM DRAIN STRUCTURES, WHEN NECESSARY, TO MEET EXISTING CONDITIONS, AS APPROVED BY MONTGOMERY COUNTY DEPARTMENT OF PERMITTING SERVICES RIGHT OF WAY INSPECTOR.
- 5. CALL "MISS UTILITY" AT 1-800-257-7777 FORTY-EIGHT (48) HOURS PRIOR TO BEGINNING
- EXCAVATION TO DETERMINE THE EXACT LOCATION OF EXISTING UTILITIES.
- 6. CLEARING IS TO BE LIMITED TO THE "LIMIT OF DISTURBANCE" AS SHOWN ON THE PLANS.
  7. ALL GRADING SHALL BE DONE IN SUCH A MANNER AS TO PROVIDE POSITIVE DRAINAGE.
- INFORMATION CONCERNING UNDERGROUND UTILITIES WAS OBTAINED FROM AVAILABLE RECORDS, BUT THE CONTRACTOR MUST DETERMINE THE EXACT LOCATIONS AND ELEVATIONS OF THE LINES BY DIGGING TEST PITS BY HAND AT ALL UTILITY CROSSINGS, WELL IN ADVANCE OF TRENCHING. IF CLEARANCES ARE LESS THAN SHOWN OR SIX (6) INCHES, WHICHEVER IS LESS, CONTACT THE COUNTY PROJECT ENGINEER, IMMEDIATELY.
- 8. REPAIRS TO UTILITIES OR PROPERTY DAMAGE AS A RESULT OF THE CONTRACTOR'S NEGLIGENCE OR METHOD OF OPERATION MUST BE MADE AT THE CONTRACTOR'S EXPENSE BEFORE PROCEEDING WITH CONSTRUCTION
- 9. DISTURBED AREAS SHALL BE GRADED AND RESTORED TO ORIGINAL CONDITIONS. DISTURBED AREAS ADJACENT TO ESTABLISHED LAWNS SHALL BE SODDED. OTHER DISTURBED AREAS SHALL BE SEEDED AND MULCHED.
- 10. THE CONTRACTOR SHALL CONTACT THE WASHINGTON SUBURBAN SANITARY COMMISSION SYSTEM MAINTENANCE ENGINEER BEFORE EXCAVATING BENEATH OR IN THE VICINITY OF EXISTING WATER OR SEWER LINES. BACKFILL SHALL BE DONE UNDER SUPERVISION OF W.S.S.C. CALL 301-699-4420. THE PROPOSED WORK AS SHOWN WILL NOT IMPACT ANY WSSL UTILITIES.
- II. ALL UTILITY POLES NOTED FOR RELOCATION SHALL BE PERFORMED BY OTHERS.
- 12. THE CONTRACTOR SHALL CONTACT WASHINGTON GAS DISPATCH OFFICER AT (703)750-4831 BEFORE EXCAVATING BENEATH OR IN THE VICINITY OF EXISTING GAS MAIN AND SERVICE LATERALS.

## CONVENTIONAL SYMBOLS EXISTING CONSTRUCTION

100 YEAR FLOODPLAIN	
RIGHT OF WAY LINE	
PROPERTY LINE	
CONCRETE CURB AND GUTTER	
EDGE OF WOODED AREAS	
TREE (FREE STANDING)	$\odot$
SIGN ·····	
FIRE HYDRANT	F.H. □Ω1 T
LIGHT POLE	<del>-</del> <del>\tilde\tau</del> -
UTILITY POLE	-0-
STORM DRAIN	
SANITARY	
WATER	w24"Ww
GAS ·····	•
ELECTRICAL HAND BOX - SIGNALS	H.B. ■
ELECTRIC (UNDERGROUND)	
WATERS OF THE U.S.	WUS
WETLAND	
WATERS EDGE	
PROPOSED	CONSTRUCTION
D. CONCTRUCTION	101 +50 102
E CONSTRUCTION	<del>- 1                                   </del>
CURB & GUTTER	
TRAVERSE POINT	
SIDEWALK	
PAVEMENT REMOVAL	
APPROXIMATE LIMITS OF CUTAND/OR FILL	
LIMIT OF DISTURBANCE	
STORM DRAIN PIPE	
SOIL BORE	B-I •
TEST PIT	TP-2 <b>⊞</b>
TEMPORARY CONSTRUCTION EASEMENT	—— TCE ————— TCE ————— TCE —
PERPETUAL EASEMENT	— PE — PE — PE —
LIMIT OF DISTURBANCE	LOD LOD LOD
ASPHALT SIDEWALK	

#### OWNER/CONTACT/ADDRESS

DEPARTMENT OF
ENVIRONMENTAL PROTECTION
MR. WILLIAM WHELAN
255 ROCKVILLE PIKE, STE 120
ROCKVILLE MD 20850-4166
240-777-7727

<u> </u>						
Ĺ		THIS APPROVAL DOES NO		DEPARTMENT O		
JMH	e Requirements:	Administrative		Sediment Contro Requireme	anagement:	Stormwater N
DESIGN	Date  Dateo Permit No.	Reviewed	Date	Reviewed		
□ SH			Date	Approved	Date	Reviewed
	PLAN WILL EXPIRE ONE YEAR FROM THE PROJECT HAS NOT STARTED HIT HAS BEEN EXTENDED	THE DATE OF APPROVAL, IF THE			Date <sub>No.</sub>	Approveds.m.file

McCORMIC TAYLOR

21202

Street

GUNNER'S LAKE
GAITHHERSBURG (9th) ELECTION DISTRICT
GUNNERS LAKE VILLAGE SUBDIVISION


ROCKVILLE, MD 20850-4166

MR. WILLIAM WHELAN

(240) 777-7727


E


Take\Design\Engineering\PlanSet\pGN-N001\_Gunners.dgn





Project No. 11-261	LOG	OF BOF	REHC	LE B-	2						Shee	et 1 of 1
CLIENT: McCormic	Taylor		ARCH	ITECT/ENG	INEEF	₹:	-					
SITE: Germantown			PROJE				ners L	_ake	EW1			
			-	SA	MPLE:	s				TEST	s	
Surface Elev.:		GRAPHIC LOG	DEPTH (FT.)	BLOWS/6" N - VALUE RQD	NUMBER	TYPE	IN. DRIVEN IN. RECOVERED	MOISTURE, %	DRY DENSITY PCF	Qu (TSF)	% Passing #200 SIEVE	ADDITIONAL DATA
3 ft of water												
Dark gray and brown FINE S/ (ML/OL) with organics and tra (Sediment), 4" sludge on the t	ce of clay		5	1-3 5-5 N=8 5-4 5-5 N=9	1		18/24 75% 20/24 83%	88				LL=44 Pl=11
7.0  Loose light brown to gray SIL (SM) with trace of gravel  9.0  End of Boring	TY FINE SAND			4-7 6-7 N=13	3	SS	18/24 75%	42				
			10—									
WATER LEVEL OBSERVATIONS		AB Cons			STA	RTED		8/26	6/13	FINISHED		8/26/13
		9450 Ann Lanham,			DRI	LL CO.		-	ABC	DRILL RIG		
		Phone: 30	01-306	-3091	DRI	LLER				ASS'T DRI	LLER	
		Fax: 301-			LOG	GED B	Υ:			APPROVE	D	

Project No. 1	11-261		<u> </u>		IOLE B-							Shee	t 1 of 1
CLIENT:	McCormick	Taylor		ARG	CHITECT/ENG	SINEEF	₹:						
SITE:				PRO	DJECT:		_						
	Germantown,	Maryland			84	MPLE	Gunners Lake EW1  IPLES TESTS						
					3,4	AVII LL	.5				1231		
				2 -				EREC	%	≽		l	ب
			9	DEPTH (FT.)	BLOWS/6" N - VALUE RQD	R		IN. DRIVEN IN. RECOVERED	MOISTURE,	DRY DENSITY PCF		% Passing #200 SIEVE	ADDITIONAL DATA
			6		0-0 NO-V-0	NUMBER	TYPE	8 W	OIST	<u>~</u> ⊬	Qu (TSF)	Pas 200 S	DDIT
Surface Elev.: 3.5 ft of w	ater			ם פ	m z č	z	F	22	Σ	۵٩	٥E	%#	₹0
					+								
				-	+								
					+								
				-	1								
3.5	FINE CANDY OF T	7M (OL) : "	.,.		1 24	_	SS	10/04	42				LL=28
organics a	FINE SANDY SILT and trace of clay (Sec	(ML/OL) with diment), sludge		-	2-1 2-2	1	55	18/24 75%	42				PI=6
4.4 Medium d	ense brown and gra	y CLAY SAND			N=3				22				
(SC) with	trace of gravel			5-	$ \!$								
					0-5	2	SS	24/24					
				// -	7-10 N=12			100%	19				
					-M								
7.5					1								
End of Bo	ring												
				-	_								
					4								
				10-	+								
WATER I EVE	OBSERVATIONS		AP Co	neulte	nte Inc	<u> </u>			0/0	2/4.0			100/40
	COUNTY	/30			nts, Inc. is Road		ARTED				FINISHED		3/23/13
			Lanhan			DR	ILL CO.		- /	ABC	DRILL RIG		
					06-3091		ILLER			- 1			









ARCHITECT/ENGINEER:  SITE:  PROJECT:  Germantown, Maryland  SAMPLES  TESTS	ARCHITECT/ENGINEER:  SITE:  Germantown, Maryland  SAMPLES  SAMPLES  TESTS  OPICIT:  SAMPLES  TESTS  TESTS  TO TESTS	ARCHITECT/ENGINEER:  SITE:  Germantown, Maryland  SAMPLES  Gunners Lake EW1  SAMPLES  TESTS  TESTS  SAMPLES  TESTS  TO SAMPLES  TO SAMPLES  TO SAMPLES  TESTS  TO SAMPLES  TO S	CLIENT: McCormick Taylor  SITE: Germantown, Maryland  Germantown, Maryland  SAMPLES  SAMPLES  TESTS  T	Project No. 11-261	LOG	OF BO	REHO	OLE B-	8						Shee	t 1 of
SITE:  Germantown, Maryland  SAMPLES  SAMPLES  TESTS  901 OF HARD SAMPLES  SAMPLES  TESTS  1	SITE:  Germantown, Maryland  Gunners Lake EW1  SAMPLES  TESTS  OD 1 (LL)  HAW BR AND SAMPLES  SAMPLES  TESTS  OD 1 (LL)  SAMPLES  TESTS  TAMPLES  TAMPLES  TAMPLES  TAMPLES  TESTS  TAMPLES  TAMPLES  TAMPLES  TAMPLES  TAMPLES  TESTS  TAMPLES  TAMPLES  TESTS  TAMPLES  TAMPLES  TAMPLES  TESTS  TAMPLES  TAMPL	SITE:  Germantown, Maryland  SAMPLES  TESTS  SUrface Elev.:  Drak gray FINE SANDY SILT (ML/OL) with organics and trace of clay (Sediment), 6" sludge on the top  3.8  Medium dense gray CLAYEY FINE SAND (SC) with trace of gravel End of Boring  PROJECT:  Gunners Lake EW1  SAMPLES  TESTS  JAM	SITE:  Germantown, Maryland  SAMPLES  TESTS  SUrface Elev.:  Drak gray FINE SANDY SILT (ML/OL) with organics and trace of clay (Sediment), 6" sludge on the top  3.8  Medium dense gray CLAYEY FINE SAND (SC) with trace of gravel End of Boring  FROJECT:  Gunners Lake EW1  SAMPLES  TESTS  JAMES JA		ok Toylor		ARCH	HTECT/ENG	SINEEF	₹:	-					
SAMPLES  SAMPLES  SAMPLES  TESTS  SAMPLES  SAMPLES  TESTS  SAMPLES  SAMPLES	Surface Elev.:    Drak gray FINE SANDY SILT (ML/OL) with organics and trace of clay (Sediment), 6" sludge on the top   Sample Sand Ples   Sand Ple	Surface Elev.:  Drak gray FINE SANDY SILT (ML/OL) with organics and trace of clay (Sediment), 6" sludge on the top  3.9  Medium dense gray CLAYEY FINE SAND (SC) with trace of gravel End of Boring  End of Boring  Cunners Lake EW1  SAMPLES  TESTS  TESTS  1	Surface Elev.:  Drak gray FINE SANDY SILT (ML/OL) with organics and trace of clay (Sediment), 6" sludge on the top  3.9  Medium dense gray CLAYEY FINE SAND (SC) with trace of gravel End of Boring  End of Boring  Cunners Lake EW1  SAMPLES  TESTS  TESTS  THAT SAMPLES  DRAW WW ALL VIII SW AND	MICCOTTIII	CK Taylor		PROJ	ECT:								
Surface Elev.:  2.4 ft of water  Drak gray FINE SANDY SILT (ML/OL) with organics and trace of clay (Sediment), 6" sludge on the top  3.9  Medium dense gray CLAYEY FINE SAND (SC) with trace of gravel End of Boring  PD D D D D D D D D D D D D D D D D D D	Surface Elev.:  2.4 ft of water  Drak gray FINE SANDY SILT (ML/OL) with organics and trace of clay (Sediment), 6" sludge on the top  3.9  Medium dense gray CLAYEY FINE SAND (SC) with trace of grawel End of Boring  Medium dense gray CLAYEY FINE SAND (SC) with trace of grawel End of Boring	Surface Elev.:  2.4 ft of water  Drak gray FINE SANDY SILT (ML/OL) with organics and trace of clay (Sediment), 6" sludge on the top  3.8  Medium dense gray CLAYEY FINE SAND (SC) with trace of gravel End of Boring  Two Line and trace of gravel End of Boring  Two Line and Trace of Lay (Sediment), 6" sludge on the top  3.9  Two Line and Trace of Lay (Sediment), 6" sludge on the top  3.9  Two Line and Trace of Lay (Sediment), 6" sludge on the top  3.9  Two Line and Trace of Lay (Sediment), 6" sludge on the top  3.9  Two Line and Trace of Lay (Sediment), 6" sludge on the top  3.9  Two Line and Trace of Lay (Sediment), 6" sludge on the top  3.9  Two Line and Trace of Lay (Sediment), 6" sludge on the top  3.9  Two Line and Trace of Lay (Sediment), 6" sludge on the top  3.9  Two Line and Trace of Lay (Sediment), 6" sludge on the top  3.9  Two Line and Trace of Lay (Sediment), 6" sludge on the top  3.9  Two Line and Trace of Lay (Sediment), 6" sludge on the top  3.9  Two Line and Trace of Lay (Sediment), 6" sludge on the top  3.9  Two Line and Trace of Lay (Sediment), 6" sludge on the top  3.9  Two Line and Trace of Lay (Sediment), 6" sludge on the top  3.9  Two Line and Trace of Lay (Sediment), 6" sludge on the top  3.9  Two Line and Trace of Lay (Sediment), 6" sludge on the top  3.9  Two Line and Trace of Lay (Sediment), 6" sludge on the top  3.9  Two Line and Trace of Lay (Sediment), 6" sludge on the top  3.9  Two Line and Trace of Lay (Sediment), 6" sludge on the top  3.9  Two Line and Trace of Lay (Sediment), 6" sludge on the top  3.9  Two Line and Trace of Lay (Sediment), 6" sludge on the top  4.1  Two Line and Trace of Lay (Sediment), 6" sludge on the top  4.1  Two Line and Trace of Lay (Sediment), 6" sludge on the top  4.1  Two Line and Trace of Lay (Sediment), 6" sludge on the top  4.1  Two Line and Trace of Lay (Sediment), 6" sludge on the top  4.1  Two Line and Trace of Lay (Sediment), 6" sludge on the top lay (Sediment), 6" sludge on the top lay (Sediment), 6" sludge on the top lay (Sediment), 6" sludge on t	Surface Elev.:    2.4 ft of water   2.4 ft of wa		n, Maryland						ners I	_ake	EW'		e .	
2.4 ft of water  2.4 ft of water  Drak gray FINE SANDY SILT (ML/OL) with organics and trace of clay (Sediment), 6" sludge on the top  3.9  Medium dense gray CLAYEY FINE SAND (SC) with trace of gravel End of Boring  LL=39 PI=10  1.4 5-7 N=9 39	2.4 To f water  Drak gray FINE SANDY SILT (ML/OL) with organics and trace of clay (Sediment), 6" sludge on the top  3.9 Medium dense gray CLAYEY FINE SAND (SC) with trace of gravel End of Boring  End of Boring  LL=39  PI=10  SS 24/24  100  SS 24/24  100  114  1 SS 24/24  100  100  100  100  100  100  100  1	2.4 To five water  2.4 Drak gray FINE SANDY SILT (MIL/OL) with organics and trace of clay (Sediment), 6" sludge on the top  3.9 Medium dense gray CLAYEY FINE SAND (SC)  4.4 With trace of gravel End of Boring  5—	2.4 To fivater  2.4 To fivater  Drak gray FINE SANDY SILT (MIL/OL) with organics and trace of clay (Sediment), 6" sludge on the top  3.9 Medium dense gray CLAYEY FINE SAND (SC)  with trace of gravel End of Boring  End of Boring  End of Boring  LL=39 PI=10  39					SA	IVIPLE	5				IESI	5	
Drak gray FINE SANDY SILT (ML/OL) with organics and trace of clay (Sediment), 6" sludge on the top  3.9  Medium dense gray CLAYEY FINE SAND (SC) with trace of gravel End of Boring	Drak gray FINE SANDY SILT (ML/OL) with organics and trace of clay (Sediment), 6" sludge on the top  3.9  Medium dense gray CLAYEY FINE SAND (SC) with trace of gravel End of Boring	Drak gray FINE SANDY SILT (ML/OL) with organics and trace of clay (Sediment), 6" sludge on the top  3.9  Medium dense gray CLAYEY FINE SAND (SC) with trace of gravel End of Boring  5—	Drak gray FINE SANDY SILT (ML/OL) with organics and trace of clay (Sediment), 6" sludge on the top  3.9  Medium dense gray CLAYEY FINE SAND (SC) with trace of gravel End of Boring  5—  ————————————————————————————————			GRAPHIC LOG	DEPTH (FT.)	BLOWS/6" N - VALUE RQD	NUMBER	TYPE	IN. DRIVEN IN. RECOVERE	MOISTURE, %	DRY DENSITY PCF	Qu (TSF)	% Passing #200 SIEVE	ADDITIONAL
				Drak gray FINE SANDY SILorganics and trace of clay (Son the top  3.9  Medium dense gray CLAYEY with trace of gravel	Sediment), 6" sludge		5—	5-7	1	SS	24/24 100%					
	WATER LEVEL OBSERVATIONS  AP Consultants Inc.	WATER LEVEL OBSERVATIONS  AP Consultants Inc.			43	9450 Anr	napolis	Road							3	o/∠6/13
WATER LEVEL OBSERVATIONS  AB Consultants, Inc. 9450 Annapolis Road  ABC DRILL BIG.  ABC DRILL BIG.  ABC DRILL BIG.  ABC DRILL BIG.	9450 Annapolis Road  PRIL CO ARC DRILL BIG	9450 Annapolis Road  ABC DRILL BIG	9450 Annapolis Road  ABC DRILL BIG		13	Lanham,	MD 20	0706							LLFR	
WATER LEVEL OBSERVATIONS  AB Consultants, Inc. started 8/26/13 Finished 8/26/13	9450 Annapolis Road Lanham, MD 20706  DRILL CO. ABC DRILL RIG	9450 Annapolis Road Lanham, MD 20706  DRILL CO. ABC DRILL RIG	9450 Annapolis Road Lanham, MD 20706  DRILL CO. ABC DRILL RIG			Phone: 301-			- Dix				-	I DIGI		

	ACTUAL FIELD BORING CO	ORDINATES
Boring No.	Easting	Northing
B-1	1239899.835	546162.576
B-2	1239870.646	545863.997
B-3	1240098.398	546194.801
B-4	1240340.276	546510.053
B-5	1240231.535	546150.724
B-6	1240162.512	545801.263
B-7	1240219.483	545895.802
B-8	1240288.332	546183.345

OWNER/CONTACT/ADDRESS

DEPARTMENT OF
ENVIRONMENTAL PROTECTION
MR. WILLIAM WHELAN
255 ROCKVILLE PIKE, STE 120
ROCKVILLE MD 20850-4166

240-777-7727

T. MONT						
CLIEN	)	THIS APPROVAL DOES NOT NEGATE THE NEED OF A MCDPS ACCESS PERMIT		DEPARTMENT O CTION APPROVE		
TWH I		Administrative Requirements:		Sediment Contro Requireme	anagement:	Stormwater Mo
DESIGN DRAFT		Reviewed Date	Date	Reviewed		
	L		Date	Approved	Date	Reviewed
SHEET 3		MCDOT APPROVAL OF THIS PLAN WILL EXPIRE ONE YEAR FROM THE DATE OF APPROVAL. IF THE PROJECT HAS NOT STARTED UNLESS THE PERMIT HAS BEEN EXTENDED			Date Io.	Approved S.M.FILE N

DATE DEC '13

SCALE NOTTO
SCALE NOTTO
SCALE AND COMMENTAL PROTECTION


255 ROCKVILLE PIKE, RM. 120
ROCKVILLE, MD 20850-4166
MR. WILLIAM WHELAN
(240) 777-7727


GUNNER'S
THHERSBURG (9th) E
UNNERS LAKE VILLA
MONTGOMERY CO


21202


ORMICI


Str














2. THE PERMITTEE MUST OBTAIN INSPECTION AND APPROVAL BY DPS AT THE FOLLOWING POINTS:

- A. AT THE REQUIRED PRE-CONSTRUCTION MEETING.
- B. FOLLOWING INSTALLATION OF SEDIMENT CONTROL MEASURES AND PRIOR TO ANY OTHER LAND DISTURBING ACTIVITY. C. DURING THE INSTALLATION OF A SEDIMENT BASIN OR STORMWATER MANAGEMENT STRUCTURE AT THE REQUIRED INSPECTION POINTS (SEE INSPECTION CHECKLIST ON PLAN). NOTIFICATION PRIOR TO COMMENCING CONSTRUCTION IS MANDATORY.
- D. PRIOR TO REMOVAL OR MODIFICATION OF ANY SEDIMENT CONTROL STRUCTURE(S). E. PRIOR TO FINAL ACCEPTANCE.

3. THE PERMITTEE SHALL CONSTRUCT ALL EROSION AND SEDIMENT CONTROL MEASURES PER THE APPROVED PLAN AND CONSTRUCTION SEQUENCE, SHALL HAVE THEM INSPECTED AND APPROVED BY THE DEPARTMENT PRIOR TO BEGINNING ANY OTHER LAND DISTURBANCES SHALL ENSURE THAT ALL RUNOFF FROM DISTURBED AREAS IS DIRECTED TO THE SEDIMENT CONTROL DEVICES, AND SHALL NOT REMOVE ANY EROSION OR SEDIMENT CONTROL MEASURE WITHOUT PRIOR PERMISSION FROM THE DEPARTMENT.

4. THE PERMITTEE SHALL PROTECT ALL POINTS OF CONSTRUCTION INGRESS AND EGRESS TO PREVENT THE DEPOSITION OF MATERIALS ONTO TRAVERSED PUBLIC THOROUGHFARE(S). ALL MATERIALS DEPOSITED ONTO PUBLIC THOROUGHFARE(S) SHALL BE REMOVED IMMEDIATELY.

5. THE PERMITTEE SHALL INSPECT PERIODICALLY AND MAINTAIN CONTINUOUSLY IN EFFECTIVE OPERATING CONDITION, ALL EROSION AND SEDIMENT CONTROL MEASURES UNTIL SUCH TIME AS THEY ARE REMOVED WITH PRIOR PERMISSION FROM THE DEPARTMENT. THE PERMITTEE IS RESPONSIBLE FOR IMMEDIATELY REPAIRING OR REPLACING ANY SEDIMENT CONTROL MEASURES WHICH HAVE BEEN DAMAGED OR REMOVED BY THE PERMITTEE OR ANY OTHER PERSON.

6. FOLLOWING INITIAL SOIL DISTURBANCE OR RE-DISTURBANCE, PERMANENT OR TEMPORARY STABILIZATION MUST BE COMPLETED WITHIN:

- A. THREE (3) CALENDAR DAYS AS TO THE SURFACE OF ALL PERIMETER DIKES, SWALES, DITCHES, PERIMETER SLOPES AND ALL SLOPES STEEPER THAN 3 HORIZONTAL TO 1 VERTICAL (3:1); AND
- B. SEVEN (7) CALENDAR DAYS AS TO ALL OTHER DISTURBED OR GRADED AREAS ON THE PROJECT SITE NOT UNDER ACTIVE GRADING. ALL AREAS DISTURBED OUTSIDE OF THE PERIMETER SEDIMENT CONTROL SYSTEM MUST BE MINIMIZED AND STABILIZED IMMEDIATELY. MAINTENANCE MUST BE PERFORMED AS NECESSARY TO ENSURE CONTINUED STABILIZATION.

7. THE PERMITTEE SHALL APPLY SOD, SEED, AND ANCHORED STRAW MULCH, OR OTHER APPROVED STABILIZATION MEASURES TO ALL DISTURBED AREAS WITHIN SEVEN (7) CALENDAR DAYS AFTER STRIPPING AND GRADING ACTIVITIES HAVE CEASED ON THAT AREA. MAINTENANCE SHALL BE PERFORMED AS NECESSARY TO ENSURE CONTINUED STABILIZATION. ACTIVE CONSTRUCTION AREAS SUCH AS BORROW OR STOCKPILE AREAS, ROADWAY IMPROVEMENTS, AND AREAS WITHIN FIFTY (50) FEET OF A BUILDING UNDER CONSTRUCTION MAY BE EXEMPT FROM THIS REQUIREMENT, PROVIDED THAT EROSION AND SEDIMENT CONTROL MEASURES ARE INSTALLED AND MAINTAINED TO PROTECT THOSE AREAS.

8. PRIOR TO REMOVAL OF SEDIMENT CONTROL MEASURES, THE PERMITTEE SHALL STABILIZE ALL CONTRIBUTORY DISTURBED AREAS WITH REQUIRED SOIL AMENDMENTS AND TOPSOIL, USING SOD OR AN APPROVED PERMANENT SEED MIXTURE AND AN APPROVED ANCHORED MULCH. WOOD FIBER MULCH MAY ONLY BE USED IN SEEDING SEASON WHEN THE SLOPE DOES NOT EXCEED 10% AND GRADING HAS BEEN DONE TO PROMOTE SHEET FLOW DRAINAGE. AREAS BROUGHT TO FINISHED GRADE DURING THE SEEDING SEASON SHALL BE PERMANENTLY STABILIZED WITHIN SEVEN (7) CALENDAR DAYS OF ESTABLISHMENT. WHEN PROPERTY IS BROUGHT TO FINISHED GRADE DURING THE MONTHS OF NOVEMBER THROUGH FEBRUARY, AND PERMANENT STABILIZATION IS FOUND TO BE IMPRACTICAL, AN APPROVED TEMPORARY SEED AND STRAW ANCHORED MULCH SHALL BE APPLIED TO DISTURBED AREAS. THE FINAL PERMANENT STABILIZATION OF SUCH PROPERTY SHALL BE COMPLETED PRIOR TO THE FOLLOWING APRIL 15.

9. THE SITE PERMIT, WORK, MATERIALS, APPROVED SC/SM PLANS, AND TEST REPORTS SHALL BE AVAILABLE AT THE SITE FOR INSPECTION BY DULY AUTHORIZED OFFICIALS OF MONTGOMERY COUNTY.

10. SURFACE DRAINAGE FLOWS OVER UNSTABILIZED CUT AND FILL SLOPES SHALL BE CONTROLLED BY EITHER PREVENTING DRAINAGE FLOWS FROM TRAVERSING THE SLOPES OR BY INSTALLING MECHANICAL DEVICES TO LOWER THE WATER DOWN SLOPE WITHOUT CAUSING FROSION. DIKES SHALL BE INSTALLED AND MAINTAINED AT THE TOP OF CUT OR FILL SLOPES UNTIL THE SLOPE AND DRAINAGE AREA TO IT ARE FULLY STABILIZED, AT WHICH TIME THEY MUST BE REMOVED AND FINAL GRADING DONE TO PROMOTE SHEET FLOW DRAINAGE. MECHANICAL DEVICES MUST BE PROVIDED AT POINTS OF CONCENTRATED FLOW WHERE EROSION IS LIKELY TO OCCUR.

11. PERMANENT SWALES OR OTHER POINTS OF CONCENTRATED WATER FLOW SHALL BE STABILIZED WITHIN 3 CALENDAR DAYS OF ESTABLISHMENT WITH SOD OR SEED WITH AN APPROVED EROSION CONTROL MATTING OR BY OTHER APPROVED STABILIZATION MEASURES.

12. SEDIMENT CONTROL DEVICES SHALL BE REMOVED, WITH PERMISSION OF THE DEPARTMENT, WITHIN THIRTY (30) CALENDAR DAYS FOLLOWING ESTABLISHMENT OF PERMANENT STABILIZATION IN ALL CONTRIBUTORY DRAINAGE AREAS. STORMWATER MANAGEMENT STRUCTURES USED TEMPORARILY FOR SEDIMENT CONTROL SHALL BE CONVERTED TO THE PERMANENT CONFIGURATION WITHIN THIS TIME PERIOD AS WELL

13. NO PERMANENT CUT OR FILL SLOPE WITH A GRADIENT STEEPER THAN 3:1 WILL BE PERMITTED IN LAWN MAINTENANCE AREAS OR ON RESIDENTIAL LOTS. A SLOPE GRADIENT OF UP TO 2:1 WILL BE PERMITTED IN NON- MAINTENANCE AREAS PROVIDED THAT THOSE AREAS ARE INDICATED ON THE EROSION AND SEDIMENT CONTROL PLAN WITH A LOW-MAINTENANCE GROUND COVER SPECIFIED FOR PERMANENT STABILIZATION. SLOPE GRADIENT STEEPER THAN 2:1 WILL NOT BE PERMITTED WITH VEGETATIVE STABILIZATION.

14. THE PERMITTEE SHALL INSTALL A SPLASHBLOCK AT THE BOTTOM OF EACH DOWNSPOUT UNLESS THE DOWNSPOUT IS CONNECTED BY A DRAIN LINE TO AN ACCEPTABLE OUTLET.

15. FOR FINISHED GRADING, THE PERMITTEE SHALL PROVIDE ADEQUATE GRADIENTS SO AS TO PREVENT WATER FROM STANDING ON THE SURFACE OF LAWNS MORE THAN TWENTY-FOUR (24) HOURS AFTER THE END OF A RAINFALL, EXCEPT IN DESIGNATED DRAINAGE COURSES AND SWALE FLOW AREAS, WHICH MAY DRAIN AS LONG AS FORTY-EIGHT (48) HOURS AFTER THE END OF A RAINFALL.

16. SEDIMENT TRAPS OR BASINS ARE NOT PERMITTED WITHIN 20 FEET OF A BUILDING WHICH IS EXISTING OR UNDER CONSTRUCTION. NO BUILDING MAY BE CONSTRUCTED WITHIN 20 FEET OF A SEDIMENT TRAP OR BASIN.

17. ALL INLETS IN NON-SUMP AREAS SHALL HAVE ASPHALT BERMS INSTALLED AT THE TIME OF BASE PAVING ESTABLISHMENT.

18. THE SEDIMENT CONTROL INSPECTOR HAS THE OPTION OF REQUIRING ADDITIONAL SEDIMENT CONTROL MEASURES, AS DEEMED NECESSARY.

19. ALL TRAP ELEVATIONS ARE RELATIVE TO THE OUTLET ELEVATION, WHICH MUST BE ON EXISTING UNDISTURBED GROUND.

20. VEGETATIVE STABILIZATION SHALL BE PERFORMED IN ACCORDANCE WITH THE STANDARDS AND SPECIFICATIONS FOR SOIL EROSION AND SEDIMENT CONTROL.

21. SEDIMENT TRAP(S)/BASIN(S) SHALL BE CLEANED OUT AND RESTORED TO THE ORIGINAL DIMENSIONS WHEN SEDIMENT HAS ACCUMULATED TO THE POINT OF ONE-HALF (1/2) THE WET STORAGE DEPTH OF THE TRAP/BASIN (1/4 THE WET STORAGE DEPTH FOR ST-III) OR WHEN REQUIRED BY THE SEDIMENT CONTROL INSPECTOR.

22. SEDIMENT REMOVED FROM TRAPS/BASINS SHALL BE PLACED AND STABILIZED IN APPROVED AREAS, BUT NOT WITHIN A FLOODPLAIN.

23. ALL SEDIMENT BASINS AND TRAPS MUST BE SURROUNDED WITH A WELDED WIRE SAFETY FENCE. THE FENCE MUST BE AT LEAST 42 INCHES HIGH, HAVE POSTS SPACED NO FARTHER APART THAN 8 FEET, HAVE MESH OPENINGS NO GREATER THE TWO INCHES IN WIDTH AND FOUR INCHES IN HEIGHT, WITH A MINIMUM OF 14 GAUGE WIRE. SAFETY FENCE MUST BE MAINTAINED IN GOOD CONDITION AT ALL TIMES.

24. NO EXCAVATION IN THE AREAS OF EXISTING UTILITIES IS PERMITTED UNLESS THEIR LOCATION HAS BEEN DETERMINED. CALL "MISS UTILITY" AT 1-800-257-7777, 48 HOURS PRIOR TO THE START OF WORK.

25. OFF-SITE SPOIL OR BORROW AREAS MUST HAVE PRIOR APPROVAL BY DPS.

26. SEDIMENT TRAP/BASIN DEWATERING FOR CLEANOUT OR REPAIR MAY ONLY BE DONE WITH THE DPS INSPECTOR'S PERMISSION. THE INSPECTOR MUST APPROVE THE DEWATERING METHOD FOR EACH APPLICATION. THE FOLLOWING METHODS MAY BE CONSIDERED:

- A. PUMP DISCHARGE MAY BE DIRECTED TO ANOTHER ON-SITE SEDIMENT TRAP OR BASIN, PROVIDED IT IS OF SUFFICIENT VOLUME AND THE PUMP INTAKE IS FLOATED TO PREVENT AGITATION OR SUCTION OF DEPOSITED SEDIMENTS: OR B. THE PUMP INTAKE MAY UTILIZE A REMOVABLE PUMPING STATION AND MUST DISCHARGE INTO AN UNDISTURBED AREA
- THROUGH A NON-EROSIVE OUTLET; OR C. THE PUMP INTAKE MAY BE FLOATED AND DISCHARGE INTO A DIRT BAG (12 OZ. NON-WOVEN FABRIC), OR APPROVED

EQUIVALENT, LOCATED IN AN UNDISTURBED BUFFER AREA. REMEMBER: DEWATERING OPERATION AND METHOD MUST HAVE PRIOR APPROVAL BY THE DPS INSPECTOR. 25. OFF-SITE SPOIL OR BORROW AREAS MUST HAVE PRIOR APPROVAL BY DPS.

26. SEDIMENT TRAP/BASIN DEWATERING FOR CLEANOUT OR REPAIR MAY ONLY BE DONE WITH THE DPS INSPECTOR'S PERMISSION. THE INSPECTOR MUST APPROVE THE DEWATERING METHOD FOR EACH APPLICATION. THE FOLLOWING METHODS MAY BE CONSIDERED:

- A. PUMP DISCHARGE MAY BE DIRECTED TO ANOTHER ON-SITE SEDIMENT TRAP OR BASIN, PROVIDED IT IS OF SUFFICIENT VOLUME AND THE PUMP INTAKE IS FLOATED TO PREVENT AGITATION OR SUCTION OF DEPOSITED SEDIMENTS; OR B. THE PUMP INTAKE MAY UTILIZE A REMOVABLE PUMPING STATION AND MUST DISCHARGE INTO AN UNDISTURBED AREA THROUGH A NON-EROSIVE OUTLET; OR
- C. THE PUMP INTAKE MAY BE FLOATED AND DISCHARGE INTO A DIRT BAG (12 OZ. NON-WOVEN FABRIC), OR APPROVED EQUIVALENT, LOCATED IN AN UNDISTURBED BUFFER AREA.

REMEMBER: DEWATERING OPERATION AND METHOD MUST HAVE PRIOR APPROVAL BY THE DPS INSPECTOR.

27. THE PERMITTEE MUST NOTIFY THE DEPARTMENT OF ALL UTILITY CONSTRUCTION ACTIVITIES WITHIN THE PERMITTED LIMITS OF DISTURBANCE PRIOR TO THE COMMENCEMENT OF THOSE ACTIVITIES.

28. TOPSOIL MUST BE APPLIED TO ALL PERVIOUS AREAS WITHIN THE LIMITS OF DISTURBANCE PRIOR TO PERMANENT STABILIZATION IN ACCORDANCE WITH MDE \*STANDARDS AND SPECIFICATIONS FOR SOIL PREPARATION, TOPSOILING, AND SOIL AMENDMENTS\*.

#### TEMPORARY SEEDING SPECIFICATIONS

1. TEMPORARY SEEDING: SHALL BE DONE BETWEEN MARCH 1 - MAY 15 AND AUGUST 15 - OCTOBER 15. ALL OTHER DISTURBED AREAS REQUIRING STABILIZATION NOT WITHIN THE SEEDING DATES SHALL BE MULCHED.

2. ALL TEMPORARY SEEDED AREAS SHALL BE MULCHED IMMEDIATELY AFTER SEEDING, MULCH MATERIALS SHOULD BE UNWEATHERED. UNCHOPPED, SMALL GRAIN STRAW SPREAD AT A RATE OF 2 TONS PER ACRE. THE MULCH SHALL BE ANCHORED IMMEDIATELY AFTER PLACEMENT WITH ASPHALT, PEG AND TWINE, PLASTIC NETTINGS OR BY A MULCH ANCHORING TOOL.

3. LIME AND FERTILIZER SHALL BE REQUIRED FOR TEMPORARY SEEDING IN ACCORDANCE WITH THE FOLLOWING PROCEDURES: 1. PULVERIZED DOLOMITIC LIMESTONE IS TO BE APPLIED AT THE RATE OF 90 LBS. PER 1,000 SQ. FT. 2. FERTILIZER SHALL BE 10-20-20 OR EQUIVALENT AND APPLIED AT THE RATE OF 10 LBS. PER 1,000 SQ. FT.

#### PERMANENT SEEDING AND SODDING SPECIFICATIONS

1. ALL DISTURBED AREAS SHALL BE SEEDED AND MULCHED.

2. SOIL PREPARATION: WEEDS AND UNDESIRABLE GRASSES GROWING ON EXISTING GRADE THAT IS TO BE SEEDED AND/OR SODDED MUST BE TOPSOIL SHALL BE TESTED AND AMENDED AS PER SOIL TEST RECOMMENDATIONS. CUT AND REMOVED BEFORE SOIL PREPARATION BEGINS. BEFORE SEEDING OR SODDING ALL SOILS SHALL BE LOOSENED BY MEANS OF FILLING AND/OR DISCING. ALL TRASH, DEBRIS, ROOTS, BRUSH, WIRE, ROCKS, STONE AND OTHER FOREIGN DEBRIS OVER ONE INCH IN DIAMETER SHALL BE REMOVED PRIOR TO SEEDING AND/OR SODDING, TO A DEPTH OF FOUR (4) INCHES.

3. TOPSOIL: THE MINIMUM ORGANIC CONTENT IN THE MSHA SPECIFICATION REFERENCED SHALL BE INCREASED TO 10%. ORGANIC MATTER SHALL BE ADDED USING COMPOST MATERIAL MEETING THE STANDARD REQUIREMENTS IN THE SPECS.

4. SEEDED PREPARATION: THE TOP LAYER OF SOIL SHALL BE LOOSENED BY DISCLING OR RAKING (SHALL BE DONE ON CONTOUR) AT A DEPTH OF AT LEAST 3", BEFORE SEEDING OCCURS. APPLY 100LBS PER 1,000 SQ.FT. OF LIME AND 15 LB. PER 1,000 SQ.FT. OF 10-10-10 FERTILIZER OR EQUIVALENT. THOROUGHLY MIX INTO SOIL TO A MINIMUM OF 3".

5. SEEDING: USE 40% KENTUCKY BLUEGRASS, 10% ANNUAL RYE AND 25% RED FESCUE AT THE RATE OF 250 LB. PER ACRE.

6. MULCHING: USE CLEAN, UNWEATHERED, UNCHOPPING SMALL GRAIN STRAW AT THE RATE OF 1.5 TO 2 TONS PER ACRE ANCHORED DOWN WITH CUTBACK ASPHALT AT THE RATE OF 5-8 GALLONS PER 1000 SQ. FT.

7. DISCING AND HARROWING SHALL BE DONE ON CONTOUR.

8. SOD SHALL BE STATE APPROVED SOD INSPECTED AND APPROVED BY MD. DEPT. OF AGRICULTURE. ALL SOD SHALL BE LAID ON SITE NO MORE THAN 36 HOURS AFTER HARVEST, AND SHALL BE A MIXTURE OF 60% (MIN.) TALL FESCUE AND 40% (MIN.) KENTUCKY BLUEGRASS.

9. SOD PEGS OR STAKES BE UNTREATED WOOD PEGS DRIVEN THROUGH, AND FLUSH WITH SOD. ALL SLOPES WITH A GRADE 3 TO 1 OR STEEPER SHALL BE PEGGED AT A MINIMUM OF 4 PEGS PER SQUARE YARD OF SOD.

10.SODDING, SEEDING AND MULCHING MAY BE DONE IMMEDIATELY AFTER FINAL GRADING, PROVIDED THAT THE BED HAS REMAINED IN GOOD, FRIABLE CONDITION AND HAS NOT BECOME MUDDY OR HARD, IF IT HAS BECOME HARD, IT SHALL BE FILLED TO FRIABLE CONDITION AGAIN.

11.SEED SHALL BE WORKED INTO THE TOP 3" OF SOIL BY MEANS OF RAKING, WIRE DRAG OR OTHER APPROVED EQUIPMENT, DURING PERIODS OF HIGH TEMPERATURE AND/OR DROUGHT. THE SOIL SHALL BE WATERED IMMEDIATELY PRIOR TO LAYING THE SOD, ALL SOD SHALL BE LAID AT RIGHT ANGLES TO SLOPES NO SOD SHALL BE APPLIED TO FROZEN GROUND AND NO FROZEN SOD IS TO BE LAID. WATERING SHALL COMMENCE IMMEDIATELY DURING OR AFTER THE LAYING OPERATION, AND SHALL BE SUFFICIENT TO THOROUGHLY WET THE

2. INSTALL SEDIMENT CONTROL DEVICES INCLUDING CONSTRUCTION ENTRANCE, SUPER SILT SOD ROOTS AND THE SOIL BELOW.

12.PERMANENT SEEDING: SHALL BE DONE MARCH 1 - MAY 15 AND AUGUST 15 - OCTOBER 15. IRRIGATION FOR PERMANENT SEEDING SHALL BE DONE BETWEEN MAY 15 AND AUGUST 14.

13.SEDIMENT CONTROL DEVICES (DITCHES, DIKES, TRAPS, ETC.) ARE TO REMAIN IN PLACE UNTIL CONTRIBUTING WATERSHED HAS BEEN STABILIZED MAINTENANCE TO SEDIMENT CONTROL DEVICES DURING THE UNDER GOING GRADING CONSTRUCTION AND DEVELOPMENT SHOULD BE DONE AS NECESSARY. REMOVAL OF THESE DEVICES SHALL BE WITH THE APPROVAL OF THE MONTGOMERY COUNTY SEDIMENT CONTROL INSPECTOR.

#### STANDARDS AND SPECIFICATIONS FOR TOPSOIL

TOPSOILING

1. TOPSOIL IS PLACED OVER PREPARED SUBSOIL PRIOR TO ESTABLISHMENT OF PERMANENT VEGETATION. THE PURPOSE IS TO PROVIDE A SUITABLE SOIL MEDIUM FOR VEGETATIVE GROWTH. SOILS OF CONCERN HAVE LOW MOISTURE CONTENT, LOW NUTRIENT LEVELS. LOW PH. MATERIALS TOXIC TO PLANTS AND/OR UNACCEPTABLE SOIL GRADATION.

2. TOPSOIL SALVAGED FROM AN EXISTING SITE MAY BE USED PROVIDED IT MEETS THE STANDARDS AS SET FORTH IN THESE SPECIFICATIONS. TYPICALLY, THE DEPTH OF TOPSOIL TO BE SALVAGED FOR A GIVEN SOIL TYPE CAN BE FOUND IN THE REPRESENTATIVE SOIL PROFILE SECTION IN THE SOIL SURVEY PUBLISHED BY USDA-NRCS.

3. TOPSOILING IS LIMITED TO AREAS HAVING 2:1 FOR FLATTER SLOPES WHERE:

- A. THE TEXTURE OF THE EXPOSED SUBSOIL/PARENT MATERIAL IS NOT ADEQUATE TO PRODUCE VEGETATIVE GROWTH. B. THE SOIL MATERIAL IS SO SHALLOW THAT THE ROOTING ZONE IS NOT DEEP ENOUGH TO SUPPORT PLANTS OR
- FURNISH CONTINUING SUPPLIES OF MOISTURE AND PLANT NUTRIENTS

4. AREAS HAVING SLOPES STEEPER THAN 2:1 REQUIRE SPECIAL CONSIDERATION AND DESIGN.

C. THE ORIGINAL SOIL TO BE VEGETATED CONTAINS MATERIAL TOXIC TO PLANTS GROWTH.

D. THE SOIL IS SO ACIDIC THAT TREATMENT WITH LIMESTONE IS NOT FEASIBLE.

5. TOPSOIL SPECIFICATIONS: SOIL TO BE USED AS TOPSOIL MUST MEET THE FOLLOWING CRITERIA:

- A. TOPSOIL MUST BE A LOAM, SANDY LOAM, CLAY LOAM, SILT LOAM, SANDY CLAY LOAM, OR LOAMY SAND. OTHER SOILS MAY BE USED IF RECOMMENDED BY AN AGRONOMIST OR SOIL SCIENTIST AND APPROVED BY THE APPROPRIATE APPROVAL AUTHORITY. TOPSOIL MUST NOT BE A MIXTURE OF CONTRASTING TEXTURED SUBSOILS AND MUST CONTAIN LESS THAN 5 PERCENT BY VOLUME OF CINDERS, STONES, SLAG, COARSE FRAGMENTS, GRAVEL, STICKS, ROOTS, TRASH, OR OTHER MATERIALS LARGER THAN 4 INCHES IN DIAMETER.
- B. TOPSOIL MUST BE FREE OF NOXIOUS PLANTS OR PLANT PARTS SUCH AS BERMUDA GRASS. QUACK GRASS. JOHNSON GRASS. NUT SLEDGE, POISON IVY, THISTLE, OR OTHERS AS SPECIFIED.
- C. TOPSOIL SUBSTITUTES OR AMENDMENTS, AS RECOMMENDED BY A QUALIFIED AGRONOMIST OR SOIL SCIENTIST AND APPROVED BY THE APPROPRIATE APPROVAL AUTHORITY, MAY BE USED IN LIEU OF NATURAL TOPSOIL

6. TOPSOIL APPLICATION

A. EROSION AND SEDIMENT CONTROL PRACTICES MUST BE MAINTAINED WHEN APPLYING TOPSOIL B. UNIFORMLY DISTRIBUTE TOPSOIL IN A 5 TO 8 INCH LAYER AND LIGHTLY COMPACTED TO A MINIMUM THICKNESS OF 4 INCHES. SPREADING IS TO BE PERFORMED IN SUCH A MANNER THAT SODDING OR SEEDING CAN PROCEED WITH A MINIMUM OF ADDITIONAL SOIL PREPARATION AND TILLAGE. ANY IRREGULARITIES IN THE SURFACE RESULTING FROM TOPSOILING OR OTHER OPERATIONS MUST BE CORRECTED IN ORDER TO PREVENT THE FORMATION OF DEPRESSIONS OR WATER POCKETS.

C. TOPSOIL MUST NOT BE PLACED IF THE TOPSOIL OR SUBSOIL IS IN A FROZEN OR MUDDY CONDITION, WHEN THE SUBSOIL IS EXCESSIVELY WET, OR IN A CONDITION THAT MAY OTHERWISE BE DETRIMENTAL TO PROPER GRADING AND SEEDBED PREPARATION. SOIL AMENDMENTS (FERTILIZER AND LIME SPECIFICATIONS)

- 1. SOIL TESTS MUST BE PERFORMED TO DETERMINE THE EXACT RATIOS AND APPLICATION RATES FOR BOTH LIME AND FERTILIZER ON SITES HAVING DISTURBED AREAS OF 5 ACRES OR MORE. SOIL ANALYSIS MAY BE PERFORMED BY A RECOGNIZED PRIVATE OR COMMERCIAL LABORATORY. SOIL SAMPLES TAKEN FOR ENGINEERING PURPOSES MAY ALSO BE USED FOR CHEMICAL ANALYSIS.
- 2. FERTILIZERS MUST BE UNIFORM IN COMPOSITION, FREE FLOWING AND SUITABLE FOR ACCURATE APPLICATION BY APPROPRIATE EQUIPMENT. MANURE MAY BE SUBSTITUTED FOR FERTILIZER WITH PRIOR APPROVAL FROM THE APPROPRIATE APPROVAL AUTHORITY. FERTILIZERS MUST ALL BE DELIVERED TO THE SITE FULLY LABELED ACCORDING TO THE APPLICABLE LAWS AND MUST BEAR THE NAME, TRADE NAME OR TRADEMARK AND WARRANTY OF THE PRODUCER.
- 3. LIME MATERIALS MUST BE GROUND LIMESTOME (HYDRATED OR BURNT LIME MAY BE SUBSTITUTED EXCEPT WHEN HYDROSEEDING) WHICH CONTAINS AT LEAST 50 PERCENT TOTAL OXIDES (CALCIUM OXIDE PLUS MAGNESIUM OXIDE). LIMESTONE MUST BE GROUND TO SUCH FINENESS THAT AT LEAST 50 PERCENT WILL PASS THROUGH A #100 MESH SIEVE AND 98 TO 100 PERCENT WILL PASS THROUGH A #20 MESH SIEVE.
- 4. LIME AND FERTILIZER ARE TO BE EVENLY DISTRIBUTED AND INCORPORATED INTO THE TOP 3 TO 5 INCHES OF SOIL BY DISKING OR OTHER SUITABLE MEANS.
- 5. WHERE THE SUBSOIL IS EITHER HIGHLY ACIDIC OR COMPOSED OF HEAVY CLAYS, SPREAD GROUND LIMESTONE AT THE RATE OF 4 TO 8 TONS/ACRE (200-400 POUNDS PER 1,000 SQUARE FEET) PRIOR TO THE PLACEMENT OF TOPSOIL.

CONSTRUCTION AND MATERIAL SPECIFICATIONS

WHERE THE SUBSOIL IS EITHER HIGHLY ACIDIC OR COMPOSED OF HEAVY CLAYS, GROUND LIMESTONE SHALL BE SPREAD AT THE RATE OF 4-8 TONS/ACRE (200-400 LBS PER 1000 SQ FT) PRIOR TO THE PLACEMENT OF TOPSOIL LIME SHALL BE DISTRIBUTED UNIFORMLY OVER DESIGNATED AREAS AND WORKED INTO THE SOIL.

TOPSOIL APPLICATION.

1. WHEN TOPSOILING, MAINTAIN NEEDED EROSION AND SEDIMENT CONTROL PRACTICES. 2. TOPSOIL SHALL BE UNIFORMLY DISTRIBUTED IN A 4-8 INCH LAYER AND LIGHTLY COMPACTED TO A MINIMUM THICKNESS OF 4 INCHES. ANY IRREGULARITIES IN THE SURFACE RESULTING FROM TOPSOILING OR OTHER OPERATIONS SHALL BE CORRECTED IN ORDER TO PREVENT THE FORMATION OF DEPRESSIONS OR WATER POCKETS. 3. TOPSOIL SHALL NOT BE PLACED WHILE THE TOPSOIL IS IN A FROZEN OR MUDDY CONDITION, WHEN THE SUBSOIL IS EXCESSIVELY WET OR IN A CONDITION THAT MAY OTHERWISE BE DETRIMENTAL TO PROPER GRADING AND SEEDBED PREPARATION.

#### SEQUENCE OF CONSTRUCTION

- 1. PRIOR TO CLEARING OF TREES, INSTALLING SEDIMENT CONTROL MEASURES, OR GRADING, A PRECONSTRUCTION MEETING MUST BE CONDUCTED ON-SITE WITH THE MONTGOMERY COUNTY DEPARTMENT OF PERMITTING SERVICES (MCDPS) SEDIMENT CONTROL INSPECTOR (240) 777-6300 (48 HOURS NOTICE), THE OWNER'S REPRESENTATIVE AND THE SITE ENGINEER.
- 2. THE LIMITS OF DISTURBANCE MUST BE FIELD MARKED PRIOR TO CLEARING OF TREES, INSTALLATION OF SEDIMENT CONTROL MEASURES, CONSTRUCTION, OR OTHER LAND DISTURBING ACTIVITIES. THE ACCESS PATH FROM WISTERIA DRIVE TO STAGING AREA SHALL BE PHOTO DOCUMENTED PRIOR TO MOBILIZING EQUIPMENT TO SITE.

PHASE 1 - STAGING AND TEMPORARY STOCK PILE AREA

- 1. CLEAR AND GRADE FOR INSTALLATION OF SEDIMENT CONTROL DEVICES, ONLY DISTURBING THE AREA NEEDED FOR INSTALLATION OF THE SEDIMENT CONTROL DEVICES. TRIM TREES AS NEEDED, WITH PRIOR APPROVAL BY THE ENGINEER.
- FENCE, TREE PROTECTION FENCING, DIVERSION FENCES, EARTH DIKES, AND TEMPORARY PIPES IMMEDIATELY STABILIZE ANY DISTURBANCE CAUSED BY THIS.
- 3. ONCE THE SEDIMENT CONTROL DEVICES ARE INSTALLED, THE PERMITTEE MUST OBTAIN WRITTEN APPROVAL FROM THE MCDPS INSPECTOR BEFORE PROCEEDING WITH ANY ADDITIONAL CLEARING, GRUBBING OR GRADING WITHIN THE STAGING AND STOCK PILE AREA.
- 4. WITH APPROVAL OF THE ENGINEER BEGIN TEMPORARY EXCAVATION AND GRADING OF STAGING AREA AND ACCESS ROAD. UPON REACHING PROPOSED GRADE AND PLACEMENT OF STONE, STABILIZE ALL DISTURBED AREAS WITH TEMPORARY SEED AND MULCH. SLOPES OF 3:1 OR STEEPER SHALL UTILIZE TYPE A MATTING INSTEAD OF MULCH. COMMENCE PLACEMENT OF DEWATERING EQUIPMENT AND SUPPORT UNITS.
- 5. DISTURBED AREAS WITHIN THE PROJECT LIMITS NOT DRAINING TO A SEDIMENT CONTROL DEVICE SHALL HAVE EITHER PERMANENT OR TEMPORARY STABILIZATION AT THE END OF EACH WORK DAY.

PHASE 2 - DREDGING

- 1. UPON COMPLETION OF THE PHASE 1 WORK AND WITH APPROVAL OF THE PROJECT ENGINEER COMMENCE DREDGING OPERATIONS. MAINTAIN ALL PERIMETER CONTROLS DURING THE DREDGING OPERATION.
- 2. STABILIZE DISTURBED AREAS ALONG THE SHORE LINE AS NEEDED TO PREVENT SEDIMENT LADEN RUNOFF FROM ENTERING THE LAKE.

PHASE 3 - RESTORATION


- 1. UPON COMPLETION OF THE DREDGING OPERATION, REMOVE STONE ACCESS ROAD AND STAGING AREA. RESTORE SITE TO PRE-EXISTING CONDITIONS AND GRADE AS SHOWN ON SHEET 9, SITE RESTORATION PLAN. PERMANENTLY STABILIZE ALL DISTURBED AREAS.
- 2. RECONSTRUCT AND PAVED PATHS, RECONSTRUCT CONCRETE BENCH PADS, REPLACE BENCHES, AND REPAIR PAVING, CURB & GUTTER AS NEEDED AS SHOWN ON SHEET 9, SITE RESTORATION PLAN UTILIZING SAME DAY STABILIZATION.
- 3. THE CONTRACTOR MUST OBTAIN WRITTEN APPROVAL FROM MCDPS INSPECTOR, PRIOR TO THE REMOVAL OF ANY SEDIMENT CONTROL DEVICE. ANY AREAS DISTURBED DURING THE REMOVAL OF E&S CONTROLS SHALL BE IMMEDIATELY STABILIZED


<u>OWNER/CONTACT/ADDRESS</u>


DEPARTMENT OF ENVIRONMENTAL PROTECTION MR. WILLIAM WHELAN 255 ROCKVILLE PIKE, STE 120 ROCKVILLE MD 20850-4166 240-777-7727

) Sc Flc Itim Itim 

GUNNI







SCALE: HORIZ. 1" = 20'

VERT. 1" = 10"

## TREE CANOPY REQUIREMENTS TABLE

TO BE COMPLETED BY THE CONSULTANT AND PLACED ON THE FIRST SHEET OF THE SEDIMENT CONTROL / STORMWATER MANAGEMENT PLAN SET FOR ALL PROJECTS.

Exempt: Yes X No If exempt under Section 55-5 of the Code, please list the applicable exemption category below trhis table

Total Property Area	Total Disturbed Area
Square Feet	Square Feet
Shade Trees Required	*Shade Trees Proposed

#### Fee in Lieu (Trees Required-Trees Proposed) x \$250

#### Required Number of Shade Trees

	Required Number	of Shade frees
Area (sq.	ft.) of Limits	Number of Shac
of Dis	sturbance	Trees Required
<u>FROM</u>	TO	
1	6,000	3
6,001	8,000	6
8,001	12,000	9
12,001	14,000	12
14,001	40,000	15

If the square footage of the limits of disturbance is more than 40,000, then the number of shade trees required must be calculated using the following formula:

(Number of Square Feet in Limits of Disturbance/40,000) x 15

\*Please list the square footage of each proposed planting area on the first sheet of the plan set


## OWNER/CONTACT/ADDRESS


DEPARTMENT OF ENVIRONMENTAL PROTECTION MR. WILLIAM WHELAN 255 ROCKVILLE PIKE, STE 120 ROCKVILLE MD 20850-4166 240-777-7727


					LNOM: T
MONTGOMERY CO. ENVIRONMENTAL PROTE			THIS APPROVAL DOES NO		CLIENT
Stormwater Management:	Sediment Contr Requireme		Administrative	Requirements:	KMS
	Reviewed	Date	Reviewed	Date	DESIGN
Reviewed Date	Approved	Date		Z I EKWIT NV.	SHE
Approved Date			MCDOT APPROVAL OF THIS PLAN THE DATE OF APPROVAL. IF THE UNLESS THE PERMIT HA	PROJECT HAS NOT STARTED	1
					I OF


GUNNEF


Str














#### LEGEND

WATER DEPTH RANGE	ELEVATION RANGE	COLOR
0'-1.41'	337.41'-336'	
1.41'-3.41'	336'-334'	
3.41-5.41'	334'-332'	
5.41'-7.41'	332'-330'	
7.41'-9.41'	330'-328'	
9.41'-11.41'	328'-326'	
11.41'-13.41'	326'-324'	
13.41'-15.41'	324'-322'	
15.41'-16.40'	330'-321.01'	

WATER SURFACE ELEVATION (WSEL) = 337.41

SHEET INDEX								
SHEET	NO.	SHEET TITLE						
1		OVERALL						
2		SOUTHERN AREA						
3		NORTHERN AREA						
4		OVERALL SEDIMENT DEPTH						

PROFESSIONAL CERTIFICATION

#### BOTTOM OF LAKE

ELEVATION - STORAGE TABLE


			BOTTOM OF	LAKE TO	WSEL			
ELEVATION	PLAN.	AREA	AV. AREA	DIF. ELV.	STORAGE	TOTAL STORAGE	TOTAL STORAGE	ELEVATION
Feet	Sq. Inch	SF	SF	Feet	Cubic Ft.	Cubic Ft.	Acre-Ft.	Feet
321.01	0.00	0.00	0.00	0.00	0.00	0	0.0000	321.01
322.00	1,290.00	1,290.00	645.00	0.99	638.55	639	0.0147	322.00
324.00	28,408.00	28,408.00	14,849.00	2.00	29,698.00	30,337	0.6964	324.00
326.00	114,781.00	114,781.00	71,594.50	2.00	143,189.00	173,526	3.9836	326.00
328.00	155,392.00	155,392.00	135,086.50	2.00	270,173.00	443,699	10.1859	328.00
330.00	186,985.00	186,985.00	171,188.50	2.00	342,377.00	786,076	18.0458	330.00
332.00	262,235.00	262,235.00	224,610.00	2.00	449,220.00	1,235,296	28.3585	332.00
334.00	742,083.00	742,083.00	502,159.00	2.00	1,004,318.00	2,239,614	51.4145	334.00
336.00	848,443.00	848,443.00	795,263.00	2.00	1,590,526.00	3,830,140	87.9279	336.00
337.41	938,016.00	938,016.00	893,229.50	1.41	1,259,453.60	5,089,593	116.8410	337.41
		_					-	

ELEVATION — STORAGE TABLE TOP OF SEDIMENT TO WSEL

ELEVATION	PLAN.	AREA	AV. AREA	DIF. ELV.	STORAGE	TOTAL STORAGE	TOTAL STORAGE	ELEVATION
Feet	Sq. Inch	SF	SF	Feet	Cubic Ft.	Cubic Ft.	Acre-Ft.	Feet
321.11	0.00	0.00	0.00	0.00	0.00	0	0.0000	321.11
322.00	153.00	153.00	76.50	0.89	68.08	68	0.0016	322.00
324.00	14,045.00	14,045.00	7,099.00	2.00	14,198.00	14,266	0.3275	324.00
326.00	101,228.00	101,228.00	57,636.50	2.00	115,273.00	129,539	2.9738	326.00
328.00	142,438.00	142,438.00	121,833.00	2.00	243,666.00	373,205	8.5676	328.00
330.00	167,818.00	167,818.00	155,128.00	2.00	310,256.00	683,461	15.6901	330.00
332.00	201,571.00	201,571.00	184,694.50	2.00	369,389.00	1,052,850	24.1701	332.00
334.00	316,900.00	316,900.00	259,235.50	2.00	518,471.00	1,571,321	36.0726	334.00
336.00	746,223.00	746,223.00	531,561.50	2.00	1,063,123.00	2,634,444	60.4785	336.00
337.41	938,016.00	938,016.00	842,119.50	1.41	1,187,388.50	3,821,833	87.7372	337.41

LOSS OF TOTAL STORAGE (VOLUME) TABLE ELEVATION Design Volume in Pond Ex. Volume in Pond Loss

## TOP OF SEDIMENT



EASTING	ELEVATION		
E:1239745.00	ELEV:353.49	RE-BAR	&

ВМ.#	NORTHING	EASTING	ELEVATION	
901	N:544682.07	E:1239745.00	ELEV:353.49	RE-BAR & CAP SET
902	N:544815.39	E:1239413.49	ELEV:353.08	RE-BAR & CAP SET
1002	N:545774.42	E:1240255.31	ELEV:340.38	SCREW IN DOCK
1003	N:545707.54	E:1239791.56	ELEV:339.49	PK NAIL SET IN PATH
1004	N:546137.34	N:1240071.18	ELEV:338.04	RE-BAR & CAP SET
1005	N:546320.39	N:1239802.60	ELEV:341.61	PK NAIL SET IN PATH

#### Gunners Lake Bathymetric Survey

Charles P. Johnson & Associates, Inc. (CPJ) was requested to complete a bathymetric survey of Gunners Lake located in Germantown, Maryland in order to determine the quantity of water in the lake and determine the quantity of sediment in the lake.

Due to the large size of the survey area, CPJ used a dual frequency sonar transducer device by Odom Hydrographic Systems augmented with HYPACK data processing software to complete the bathymetric survey for the southern area of the lake defined as south of the north end on the island. Due to the shallow depth of water in the northern area of the lake, CPJ used conventional measurement techniques for the depth of water and depth of sediment. In these shallow areas CPJ also used a GeoXH portable GPS data collection device by Trimble with elevation data collected using a standard survey range pole. All measurements were collected and are displayed in the Maryland State Plane Coordinates NAD 83 /NSRS 2007 horizontal datum and NAVD 1988 vertical datum established using GPS methods and using NGS CORS network.

Topographic information was collected by the transducer at regular intervals over the extent of the survey area. At each survey location, two elevations were recorded: one elevation reflecting the elevation of the top of sediment layer and one elevation reflecting the bottom of the lake (beneath the sediment layer). In addition, survey information was collected for the location and elevation of the edge of water.

#### Bathymetric Analysis

After the bathymetric survey data was post-processed using the HYPACK software to remove any anomalies, the data was input into Land Desktop, a software add-on to Autodesk's AutoCAD 2009 program. Two surfaces were generated: one reflecting the topography of the top of sediment and one reflecting the topography of the bottom of the lake. Using Land Desktop, the two surfaces were compared. Their volumetric difference represents the volume of sediment that is in the lake. Topographic contours were generated from the collected survey information using Land Desktop. These contours were produced on two (2) foot intervals and an elevation versus storage table was computed for both surfaces. A comparison of the two tables shows that sedimentation of the pond has caused an approximate 25% loss in storage or approximately 47,000 CY of sediment. This confirmed the results of the surface comparison.

AS-SHOWN After completing post-processing of all survey data and computing the sedimentation values in the basin, CPJ prepared exhibits showing topography, water depths (via color state of the sedimentation values in the basin, CPJ prepared exhibits showing topography, water depths (via color state of the sedimentation values in the basin, CPJ prepared exhibits showing topography, water depths (via color state of the sedimentation values in the basin, CPJ prepared exhibits showing topography, water depths (via color state of the sedimentation values in the basin, CPJ prepared exhibits showing topography). chart), and sedimentation depths in the lake.

I HEREBY CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME, AND THAT I AM A DULY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MARYLAND, LICENSE NUMBER: EXPIRATION DATE: 06-20-2014OVERALL


BATHYMETRIC SURVEY GUNNERS LAKE
GERMANTOWN (2nd) ELECTION DISTRICT


MONTGOMERY COUNTY, MARYLAND


Charles P. Johnson & Associates, Inc. Civil and Environmental Engineers • Planners • Landscape Architects • Surveyors

1751 Elton Rd., Ste. 300 Silver Spring, MD 20903 301.434.7000 Fax: 301.434.9394 www.cpja.com • Silver Spring, MD • Gaithersburg, MD • Frederick, MD • Fairfax, VA

CLIENT: Montgomery County Dept. of Environmental Protection 255 Rockville Pike, Suite 120	PRELIM <b>I</b> NARY PLAN NO N/A	SITE PLAN NO:		
Rockville, MD 20850 Telephone: (240) 777-7760	DESIGN ADG	SHEET	OF .	L
Contact: Gene Gopenko	DRAFT ADG	14	18	Xrefs
COPYRIGHT© LATEST DATE HEREON CHARLES P. JOHNSON & ASSOCIATES, INC. ALL RIGHTS	DATE NOV., 2012	FILE NO :		\ pau
RESERVED, UNAUTHORIZED USE OR REPRODUCTION IS PROHIBITED.	SCALE AS-SHOWN	35-57	5-30.4	tack







### BOTTOM OF LAKE

#### TOP OF SEDIMENT

#### DEPTH OF SEDIMENT

	ELEVATION — STORAGE TABLE BOTTOM OF LAKE TO WSEL										
ELEVATION	PLAN.	AREA	AV. AREA	DIF. ELV.	STORAGE	TOTAL STORAGE	TOTAL STORAGE	ELEVATION			
Feet	Sq. Inch	SF	SF	Feet	Cubic Ft.	Cubic Ft.	Acre-Ft.	Feet			
321.01	0.00	0.00	0.00	0.00	0.00	0	0.0000	321.01			
322.00	1,290.00	1,290.00	645.00	0.99	638.55	639	0.0147	322.00			
324.00	28,408.00	28,408.00	14,849.00	2.00	29,698.00	30,337	0.6964	324.00			
326.00	114,781.00	114,781.00	71,594.50	2.00	143,189.00	173,526	3.9836	326.00			
328.00	155,392.00	155,392.00	135,086.50	2.00	270,173.00	443,699	10.1859	328.00			
330.00	185,922.00	185,922.00	170,657.00	2.00	341,314.00	785,013	18.0214	330.00			
332.00	238,631.00	238,631.00	212,276.50	2.00	424,553.00	1,209,566	27.7678	332.00			
334.00	608,287.00	608,287.00	423,459.00	2.00	846,918.00	2,056,484	47.2104	334.00			

ON	PLAN.	AREA	AV. AREA	DIF. ELV.	STORAGE	TOTAL STORAGE	TOTAL STORA
	Sq. Inch	SF	SF	Feet	Cubic Ft.	Cubic Ft.	A cre-Ft.
.11	0.00	0.00	0.00	0.00	0.00	0	0.0
2.00	153.00	153.00	76.50	0.89	68.08	68	0.0
1.00	14,045.00	14,045.00	7,099.00	2.00	14,198.00	14,266	0.3
600	101 228 00	101 228 00	57 636 50	2 00	115 273 00	129 539	2.9

	ELEVATION — STORAGE TABLE TOP OF SEDIMENT TO WSEL											
AN.	AREA	AV. AREA	DIF. ELV.	STORAGE	TOTAL STORAGE	TOTAL STORAGE	ELEVATION					
Inch	SF	SF	Feet	Cubic Ft.	Cubic Ft.	A cre-Ft.	Feet					
			·									
0.00	0.00	0.00	0.00	0.00	0	0.0000	321.11					
153.00	153.00	76.50	0.89	68.08	68	0.0016	322.00					
14,045.00	14,045.00	7,099.00	2.00	14,198.00	14,266	0.3275	324.00					
101,228.00	101,228.00	57,636.50	2.00	115,273.00	129,539	2.9738	326.00					
142,438.00	142,438.00	121,833.00	2.00	243,666.00	373,205	8.5676	328.00					
167,818.00	167,818.00	155,128.00	2.00	310,256.00	683,461	15.6901	330.00					
201,571.00	201,571.00	184,694.50	2.00	369,389.00	1,052,850	24.1701	332.00					
307,381.00	307,381.00	254,476.00	2.00	508,952.00	1,561,802	35.8540	334.00					
634,829.00	634,829.00	471,105.00	2.00	942,210.00	2,504,012	57.4842	336.00					
754,678.00	754,678.00	694,753.50	1.41	979,602.44	3,483,615	79.9728	337.41					

LOSS OF TOTAL STORAGE (VOLUME) TABLE								
ELEVATION	Design Volume in Pond	Ex. Volume in Pond	Loss	Loss				
Feet	CF	CF	CF	%				
				1				
				1				
321.01	0	0	0.00	0.00%				
322.00	639	68	570.47	89.34%				
324.00	30,337	14,266	16,070.47	52.97%				
326.00	173,526	129,539	43,986.47	25.35%				
328.00	443,699	373,205	70,493.47	15.89%				
330.00	785,013	683,461	101,551.47	12.94%				
332.00	1,209,566	1,052,850	156,715.47	12.96%				
334.00	2,056,484	1,561,802	494,681.47	24.05%				
336.00	3,357,877	2,504,012	853,864.47	25.43%				
337.41	4,378,564	3,483,615	894,949.75	20.44%				

#### Southern Area of Gunners Lake Bathymetric Survey


Charles P. Johnson & Associates, Inc. (CPJ) was requested to complete a bathymetric survey of the lower reaches (approximately 17.3 acres) of Gunners Lake located in Germantown, Maryland in order to determine the quantity of water in the lake and determine the quantity of sediment in the lake.


Due to the large size of the survey area, CPJ used a dual frequency sonar transducer device by Odom Hydrographic Systems augmented with HYPACK data processing software to complete the bathymetric survey for the southern area of the lake defined as south of the north end of the island. All measurements were collected and are displayed in the Maryland State Plane Coordinates NAD 83 /NSRS 2007 horizontal datum and NAVD 1988 vertical datum established using GPS methods and using NGS CORS network.

Topographic information was collected by the transducer at regular intervals over the extent of the survey area. At each survey location, two elevations were recorded: one elevation reflecting the elevation of the top of sediment layer and one elevation reflecting the bottom of the lake (beneath the sediment layer). In addition, survey information was collected for the location and elevation of the edge of water.

#### Bathymetric Analysis

After the bathymetric survey data was post-processed using the HYPACK software to remove any anomalies, the data was input into Land Desktop, a software add-on to Autodesk's AutoCAD 2009 program. Two surfaces were generated: one reflecting the topography of the top of sediment and one reflecting the topography of the bottom of the lake. Using Land Desktop, the two surfaces were compared. Their volumetric difference represents the volume of sediment that is in the lake. Topographic contours were generated from the collected survey information using Land Desktop. These contours were produced on two (2) foot intervals and an elevation versus storage table was computed for both surfaces. A comparison of the two tables shows that sedimentation of the pond has caused an approximate 20% loss in storage or approximately 33,200





#### LEGEND

WATER DEPTH RANGE	ELEVATION RANGE	COLOR		
0'-1.41'	337.41'-336'			
1.41'-3.41'	336'-334'			
3.41-5.41	334'-332'			
5.41'-7.41'	332'-330'			
7.41'-9.41'	330'-328'			
9.41'-11.41'	328'-326'			
11.41'-13.41'	326'-324'			
13.41'-15.41'	324'-322'			
15.41'-16.40'	330'-321.01'			
WATED CLIDEACE ELEVATION				

WATER SURFACE ELEVATION (WSEL) = 337.41

PROFESSIONAL CERTIFICATION I HEREBY CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME, AND THAT I AM A DULY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MARYLAND, LICENSE NUMBER: EXPIRATION DATE: 06-20-2014

SOUTHERN AREA BATHYMETRIC SURVEY


GUNNERS LAKE
GERMANTOWN (2nd) ELECTION DISTRICT MONTGOMERY COUNTY, MARYLAND




Charles P. Johnson & Associates, Inc. Civil and Environmental Engineers • Planners • Landscape Architects • Surveyors

1751 Elton Rd., Ste. 300 Silver Spring, MD 20903 301.434.7000 Fax: 301.434.9394 www.cpja.com • Silver Spring, MD • Gaithersburg, MD • Frederick, MD • Fairfax, VA

	PRELIMINARY PLAN NO SITE PLAN NO:		
Dept. of Environmental Protection 255 Rockville Pike, Suite 120	N/A	N/A	
Rockville, MD 20850 Telephone: (240) 777-7760	DESIGN ADG	SHEET	OF
Contact: Gene Gopenko	DRAFT ADG	15	18
COPYRIGHT© LATEST DATE HEREON CHARLES	DATE		
P. JOHNSON & ASSOCIATES, INC. ALL RIGHTS RESERVED, UNAUTHORIZED USE OR	NOV., 2012	FILE NO :	
REPRODUCTION IS PROHIBITED.	SCALE AS-SHOWN	35-575-30.4	





LEGEND							
SEDIMENT DEPTH RANGE	SEDIMENT DEPTH AREA (sf)	COLOR					
0'-1'	382,905						
1'-2'	347,848						
2'-3'	167,769						
3'-4'	54,040						
4'-5'	1,656						
5'-6'	360						
6'-7'	140						

PROFESSIONAL CERTIFICATION I HEREBY CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME, AND THAT I AM A DULY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MARYLAND, LICENSE NUMBER: 32457 EXPIRATION DATE: 06-20-2014

OVERALL SEDIMENT DEPTH BATHYMETRIC SURVEY

GUNNERS LAKE
GERMANTOWN (2nd) ELECTION DISTRICT
MONTGOMERY COUNTY, MARYLAND

Charles P. Johnson & Associates, Inc.

Civil and Environmental Engineers • Planners • Landscape Architects • Surveyors Associates

Civil and Environmental Engineers • Planners • Landscape Architects • Surveyors

1751 Elton Rd., Ste. 300 Silver Spring, MD 20903 301.434.7000 Fax: 301.434.9394 www.cpja.com • Silver Spring, MD • Gaithersburg, MD • Frederick, MD • Fairfax, VA

FILE NO:

35-575-30.4

CLIENT: Montgomery County
Dept. of Environmental Protection
255 Rockville Pike, Suite 120
Rockville, MD 20807 Telephone: (240) 777-7760 Contact: Gene Gopenko COPYRIGHT© LATEST DATE HEREON CHARLES
P. JOHNSON & ASSOCIATES, INC. ALL RIGHTS
RESERVED, UNAUTHORIZED USE OR
REPRODUCTION IS PROHIBITED. DATE NOV., 2012

Last Saved 11/29/2012 Last Plotted ---- Sheet N:\35575\GUNNERS-LAKE\DWG\30-04-N

